

PROFORMA REGARDING SAFE DRINKING WATER CERTIFICATE

Date: 10 Jan 2023

It is certified that an inspection team headed by Anil Kumar Singh
(Assistant Engineer) (Name of
Department/Office) inspected the ST. PETER'S SCHOOL (ENG.
MED.) PURNEA, BISHOP HOUSE, MAHARAJAJI HATA (Name &
Address of the School) on 10 Jan 2023 and found that the ST. PETER'S
SCHOOL (ENG. MED.) PURNEA, BISHOP HOUSE,
MAHARAJAJI HATA (Name of School) has safe drinking water facilities
for the students and members of staff of the institution.

Signature with seal: _____

2/10/23
महामक अभियन्ता
लोक स्वास्थ्य अवर प्रमण्डल
समिती (पुर्विका)

Name: ANIL KUMAR SINGH

Designation: ASSISTANT ENGINEER

To

St. Peter's School (Eng. Med.)

Purnea, Bishop House

Maharajaji Hata, Purnea, Bihar (854301)

(Name & Address of the Institution)


MANAGER

ST. PETER'S SCHOOL ENGLISH MEDIUM
BISHOP'S HOUSE, MAHARAJAJI HATA,
PURNEA, BIHAR, 854301



PRINCIPAL
ST. PETER'S SCHOOL, ENGLISH MEDIUM
BISHOP'S HOUSE, MAHARAJAJI HATA,
PURNEA, BIHAR, 854301

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

District Name: Purnea

Division Name: P.H.Division, Purnea

Month: January-2023

Sl. No.	Block	Panchyat	Village/Habitation	Location of Source	Latitude		Longitude		pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coll														
					N Min.	E Min.	Sec.	Sec.																													
1	Purnea East	Nagar Nilgam Purnea	Maharaji Hata Purnea	ST. Peter English Medium School Purnea (T/M)					7.1	5	480	220	100	60	18	6.8	70	0.4	BDL	60	0.6	BDL	NEGATIVE														
Desirable Limit*																							6.5-8.5	5.0	-	500	300	75	30	250	200	1.0	BDL	200	1.0	0.01	NEGATIVE
Permissible Limit* in absence of alternate source																							NR	10.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	NEGATIVE

[Signature]
Lab Assistant/chemist
P.H. Division, Purnea

[Signature]
A.E.
P.H. Sub Division, Purnea

[Signature]
Executive Engineer
P.H. Division, Purnea

[Signature]
MANAGER
ST. PETER'S SCHOOL ENGLISH MEDIUM
BISHOP'S HOUSE, MAHARAJAJI HATA
PURNEA, BIHAR, 854301

[Signature]
PRINCIPAL
ST. PETER'S SCHOOL ENGLISH MEDIUM
BISHOP'S HOUSE, MAHARAJAJI HATA,
PURNEA, BIHAR, 854301